

**October 6, 2014**  
**BOARD OF COUNTY COMMISSIONERS**  
**ORANGE COUNTY, FLORIDA**  
**Addendum No. 4 IFB Y15-701-RM**  
**CORRECTIONS - MAIN COMMUNICATIONS ROOM UPGRADES**

**Revised Bid Opening Date: October 9, 2014 at 2:00 P.M.**

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strike through~~.

A. The bid opening date is changed from ~~October 7, 2014 at 2:00 P.M.~~ to October 9, 2014 at 2:00 P.M.

B. Additions, Deletions, Clarifications

1. **Question:** Will structural / as build plans be available for review? This will help in determining the type of slabs, the number of masonry / cast-in-place bulkheads that will have to be cored, as well as the amount of rebar involved.

**Answer:** Yes, as-built plans will be available to the winning bidder.

2. **Question:** Is there a count of how many counters will need to be modified to accommodate the new equipment in the different control rooms?

**Answer:** We count one control room with counters that will need modification.

3. **Question:** Who will be responsible for the existing penetrations that have not been previously caulked properly to meet the rating requirements?

**Answer:** For Bidding purposes, assume fifty (50) existing penetrations will need to be fire-caulked. Contractor is responsible for fire safing any and all new penetrations through rated walls/ceilings

4. **Question:** Can someone confirm that only acoustical ceilings will need to be relocated to install conduit? Otherwise, can someone verify if hard ceilings will need to be cut and their locations determined to install conduit in the electrical rooms, hall ways, communication rooms or control rooms?

**Answer:** For Bidding purposes, assume there will be two (2) areas of thirty (30) LF which will have these gyp ceilings.

**C. ACKNOWLEDGEMENT OF ADDENDA**

1. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.
2. Receipt acknowledged by:
3. All other terms and conditions of the IFB remain the same.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date Signed

\_\_\_\_\_  
Title

\_\_\_\_\_  
Name of Firm