### January 27, 2015 BOARD OF COUNTY COMMISSIONERS ORANGE COUNTY, FLORIDA Addendum No. 3, IFB Y15-740-SB ORANGE COUNTY PARKS AND RECREATION WAREHOUSE HVAC REPLACEMENT

### Bid Opening Date: February 3, 2015 at 2:00 P.M.

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. <u>Underlining</u> indicates additions, deletions are indicated by <u>strikethrough</u>.

- A. The bid opening date remains February 3, 2015 at 2:00 P.M.
- B. Additions, Deletions and Clarifications:
  - **1. Question:** Is there a specific control contractor? (JCI, Siemens, etc.)

**Answer:** The following manufacturers are acceptable: Trane, Johnson Controls, Inc, Automated Logic, Reliable Controls, and Honeywell.

**2. Question:** During the site walkthrough which occurred on January 20, 2015, additional clarification was requested related to the wall construction reflected in Section A3/A8.01 and Section A4/A8.01 due to possible conflict with existing electrical boxes.

**Answer:** Drawing Sheets A-3.0.1 & A-8.0.1 (attached) have been revised to address this. Summary of changes is noted below:

- Sheet A-3.0.1 Dated 12-01-2014 with Revision 2 date of 1/26/2015: ADD: New interior wall section identification marker depicting wall assembly on the interior of warehouse facility space. REMOVE: Conflicting sheet note 09 01 50.9100 identifying existing ACT for patch and repair.
- Sheet A-8.0.1 Dated 12-01-2014 with Revision 2 date of 1/26/2015: ADD: Typical wall section on interior of warehouse facility space added for clarity.
- 3. Question: There is no mention of O.A. (outside air) motorized dampers to be added anywhere on the plans. However there is one in the detail drawings on the controls page. Are these to be added to each system? If so, will the manual dampers in place need to be removed?

**Answer:** The intent is to use the existing manual damper as typical manual volume damper to set the outdoor air volume per air handling schedule (testing & balancing) and add the motorized damper which would just open to its full open position when its AHU supply fan is running and close fully when AHU supply fan is deactivated/off. Otherwise the outdoor air damper must adjusted to limit the amount of outdoor air for each air handling unit (testing & balancing) and fully open the existing manual volume damper. The intent was not to remove the existing manual volume damper at each existing outside air duct take-off. It works either way for Test and Balance.

## C. ACKNOWLEDGEMENT OF ADDENDA


- 1. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later that the date and time for receipt of the bid or proposal.
- 2. All other terms and conditions of the IFB remain the same.
- 3. Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm



NOTATION LIST		
DIVISION #		
NUMERIC NOTE DESIGN		
XXXXX.XX	NOTATION	
01 56 09.0000	TYPICAL, PROVIDE TEMPORARY FLOOR	
	PROTECTION DURING CONST. OPERATIONS	
02 44 09.5123	REMOVE ALL EXISTING ACOUSTICAL CEILING TILE, GRID, WIRE HANGERS AND TEES	
05 50 00.0001	METAL FABRICATIONS, METAL CLOSURE STRIP TO RUN CONTINUOUS ALONG BUILDING PERIMETER	
05 50 00.0002	TYPICAL, METAL FABRICATIONS FOAM CLOSURE STRIP INSERT	
05 50 00.0003	METAL FABRICATIONS, SECURE METAL TRIM TO WALL WITH 1 1/2" MASONRY SCREWS @ MAX. 12" O.K.	
07 21 16.0000	BLANKET INSULATION, R-VALUE R-38 @ 12" THICKNESS	
07 21 29.0000	SPRAYED INSULATION, R-VALUE R-19 @ 4" THICKNESS MINIMUM.	
07 84 43.0000	TYPICAL, PENETRATION FIRESTOPPING	
09 22 36.2300	TYPICAL, CONTINUOUS GALVANIZED WIRE MESH SECURED TO JOIST WITH SCREWS AND WASHER PLATES FOR MINERAL WOOL INSULATION SUPPORT	
09 51 23.0000	INSTALL NEW ACOUSTICAL CEILING TILES	
23 37 13.0000	DIFFUSERS, REGISTERS, AND GRILLES. REFER TO HVAC	
26 01 50.5100	LUMINAIRE RELAMPING - TYPICAL, RELAMP ALL EXISTING LIGHT FIXTURES TO REMAIN. REFER TO ELECTRICAL	

# SHEET NOTES

- SEAL ALL PENETRATIONS OCCURRING ALONG LENGTH OF RATED WALL, TYPICAL.
- $\langle 2 \rangle$  NOT USED
- 3 REMOVE AND RE-TRIM ENTIRE PERIMETER OF EXISTING WALL SEE C3/A-8.0.1 FOR ADDITIONAL INFO.

# REFLECTED CEILING LEGEND

 $\bigcirc$ 

 $\mathbb{X}$ 

 $(\mathbf{F})$ 

 $\bigcirc$ 

 $\otimes$ 

2'X4' LAY-IN FLUORESCENT LIGHT FIXTURE

2'X2' LAY-IN FLUORESCENT LIGHT FIXTURE

RECESSED DOWNLIGHT

4' X 4" FLUORESCENT LIGHT FIXTURE

- 1' X 4' FLUORESCENT LIGHT FIXTURE  $\vdash$  - - - - - - - UNDER CABINET TASK LIGHT
  - FIXTURE EMERGENCY LIGHT
  - HVAC SUPPLY
  - HVAC RETURN
  - HVAC RETURN
  - SPEAKERS
  - FIRE
  - OCCUPANCY SENSOR
  - TYP. SPRINKLER HEAD (SEE FIRE PROTECTION)
  - EMERGENCY EXIT LIGHT
  - WALL MOUNTED EMERGENCY EXIT LIGHT



MATERN PROFESSION ENGINEERING MEP/FP Engineering Consultants - A Solution Based Firm Professional ENGINEERING WEP/FP Engineering Consultants - A Solutions Based Firm ORLANDO I Fort Myers I Jacksonville I Tampa Matern Professional Engineering, Inc 130 Candace Drive Maitland, FI 32751-3331 PHONE (407) 740-5020 FAX (407) 740-0365 THIS DRAWING IS THE PROPERTY OF MATERN PROFESSIONAL ENGINEERING, INC. UNLESS OTHERWISE PROVIDED BY THE CONTRACT, THE CONTENTS OF THIS DRAWING SHALL NOT BE TRANSMITTED TO ANY OTHER PARTY EXCEPT AS AGREED TO BY THE ENGINEER. ENG. BUS. No. EB-0005096 CERT. OF AUTH. No. 5096 **ORANGE COUNTY** PARKS AND RECREATION FACILITY WAREHOUSE HVAC REPLACEMENT MIGUEL LAZARO MARTIN AR NO. 8255 SEAL Revisions Description No. Date 
 1
 01/13/2015
 REVISION #1

 2
 01/26/2015
 REVISION #2
Key Plan MPE PROJ#: 2013-212A Designed By: MLN Drawn By: SE Checked By: MLM Issue Date: 12/01/14 N.T.S Drawing Scale: Drawing Title: REFLECTED **CEILING PLANS DEMOLITION RCP** / PROPOSED RCP **BID/PERMIT** DOCUMENTS Drawing No. A-3.0.1

