# January 27, 2015

### BOARD OF COUNTY COMMISSIONERS ORANGE COUNTY, FLORIDA

### ADDENDUM No. 2 / IFB No.Y15-741-PH PUMP STATIONS No.'s 3257 BAY LAKES GRANADA, 3335 RAMSGATE CIRCLE, 3514 CYPRESS POINT PHASE 1 AND 3526 CYPRESS POINT PHASE 2 IMPROVEMENTS PACKAGE No. 7

## BID OPENING DATE: February 10, 2015

This Addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by **underlining**, deletions are indicated by strikethrough.

### A. CLARIFICATIONS

- 1. Q: Can you please tell me if the water control gates have been prepurchased in this project. There are no specifications regarding the gates they are only listed on the gird which I have attached.
  - A: Water Control gates or Sluice gates are only required for master pump stations with 4 or more pumps. All pump stations included in the scope of this project are duplex pump stations which do not require sluice gates.

# 2. Q: Am I to understand that the wet well liner required will be an HDPE lining system?

A: The existing wet wells and existing manholes shall be lined with an FRP liner, as listed in Appendix D.

# 3. Q: Will the County require both prime and subcontractors to have a FL license, or just the Prime?

A: Yes, both prime and subcontractors shall have a Florida license related to their field of work.

# B. ACKNOWLEDGEMENT OF ADDENDA

- a. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of proposal.
- b. All other terms, conditions and specifications remain the same.

c. Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm