

July 9, 2015
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
Addendum No. 12, IFB Y15-766-RM

WILLOW STREET COMMUNITY CENTER HVAC REPLACEMENT

Bid Opening Date; July 28, 2015 at 2:00 P.M.

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The bid opening date remains July 28, 2015 at 2:00 p.m.

B. Questions and Reponses

Question – A-2 “Finishes” note 09250.06 indicates typical type “X” 5/8” gypsum board. A-3 “Thermal & Moisture Protection” note 07210.01 indicates R-38 Batt Insulation, and “Finishes” note 09250.03 indicates as well typical 5/8” gypsum board. None of these notes clarify if the areas that are being pointed out with these notes signify if they are new materials or if they are existing and to remain. Can you please clarify if the indicated materials are to be new or existing to remain?

Response – Indicated materials are new.

C. ACKNOWLEDGEMENT OF ADDENDA

1. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.
2. All other terms and conditions of the IFB remain the same.
3. **Receipt acknowledged by:**

Authorized Signature

Date Signed

Title

Name of Firm

Y15-766
Addendum #12
July 9, 2015