

June 26, 2015
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
Addendum No. 9, IFB Y15-766-RM

WILLOW STREET COMMUNITY CENTER HVAC REPLACEMENT

Bid Opening Date, June 30, 2015

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The bid opening date remains June 30, 2015 at 2:00 p.m.

B. Questions and Answers

1. Question – What are the power company fees?

Response – The estimated cost for upgrading the electric lines from Willow Street north along Day Care Center Road up to the existing transformer pole feeding the community center with 3 phase service is \$14,500.

C. ACKNOWLEDGEMENT OF ADDENDA

1. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.

2. All other terms and conditions of the IFB remain the same.

3. **Receipt acknowledged by:**

Authorized Signature

Date Signed

Title

Name of Firm