

July 22, 2015

**BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA**

**ADDENDUM NO. 3 / IFB NO. Y15-792-J2
PEPPERMILL POND EROSION CONTROL**

BID OPENING DATE: July 28, 2015

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

THE BID OPENING DATE REMAINS UNCHANGED.

BID OPENING DATE: July 28, 2015

1. The following are responses to bidder questions

Question 1: Is the entire pond bottom to be graded to an elevation of 76 FT?

Response: Refer to plan sheets 6-10. No deviations from the plans should be made.

Question 2: If the entire pond bottom is to be graded to an elevation 76 FT, can existing contours be provided?

Response: All available contours are provided in the plans.

Question 3: Can we over-excavate the pond bottom to mitigate import of fill?

Response: No, the pond should not be over excavated. Clean fill is needed.

Question 4: Can our de-watering be discharged into existing outfall structures?

Response: If the Contractor wishes to do this as part of their means and methods, a permit may be required from FDEP.

2. All other terms, conditions and specifications remain the same.

3. a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.

b. Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm