

January 5, 2016
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA

Y16-714-CH/Addendum #3

**WILDWOOD AREA ROAD NETWORK - POND C - UNDERDRAIN AND SLURRY
TRENCH IMPROVEMENTS PROJECT**

Bid Opening Date: January 12, 2016

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The Bid Opening Date shall remain as follows:

January 12, 2016 at 2:00 P.M.

B. The following is a response to a question received from an interested bidder:

1. **Question:** For the Tensar Triaxial Geogrid in the clay core detail. What model / spec is the county looking for? Is Mirafi Biaxial geogrids an approved alternate?

Response: Use Tensar triaxial geogrid TX130 as specified in the construction plans and Terracon report H1135227 in Part G in the Invitation for Bids. A stronger Tensar triaxial geogrid can be used if approved by the Engineer in advance and with no additional cost to the County.

C. All other terms and conditions of the IFB remain the same.

D. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the proposal.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm