

**August 17, 2016**  
**BOARD OF COUNTY COMMISSIONERS**  
**ORANGE COUNTY, FLORIDA**  
**ADDENDUM NO. 4 / IFB NO. Y16-793-RM**  
**APOPKA & OCOEE SERVICE CENTERS AHU UPGRADE AND CHILLED WATER**  
**PIPING REPLACEMENT**

**THE REVISED BID OPENING DATE IS AUGUST 23, 2016**

This Addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strike through~~.

**A. THE BID OPENING DATE IS CHANGED from ~~August 18, 2016 at 2:00 P.M.~~ to August 23, 2016 at 2:00 P.M.**

**B.** The following Question/Response is provided:

**Question:** RFI Answer #2 does not reflect the true condition of the racks within the Apopka Service Ctr. Comm. Rm. The racks are located under the outside air ductwork and existing duct heaters that need to be replaced. Below is a link to a Drop Box with photos showing the obstructions of space needed in order to replace these items. It is recommended that temporary removal of the racks be done in order to replace the o/a ductwork and heaters.

<https://www.dropbox.com/sh/xr9opgfh2z058of/AAAiUDFIJtqhRUozFXwoBhVa?dl=0>

**Answer:** All work in the communication room must be done with the racks in place and operational. The racks are mostly on the south side of the room. The new duct heaters may be located further down the duct on the north side of the communication room. Again, the communication racks will stay in place and operational and will not be removed or relocated and the bidders will have to account for the communication racks being in place and operational and will not be removed or relocated in this project.

**C.** All other terms, conditions and specifications remain the same.

The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.

Receipt acknowledged by:

\_\_\_\_\_  
**Authorized Signature**

\_\_\_\_\_  
**Date Signed**

\_\_\_\_\_  
**Title**

\_\_\_\_\_  
**Name of Firm**