

**September 6, 2016**  
**BOARD OF COUNTY COMMISSIONERS**  
**ORANGE COUNTY, FLORIDA**  
**Y16-795-RM / Addendum No. 4**  
**ORANGE COUNTY COURTHOUSE COMPLEX AIR HANDLING UNITS**  
**REPLACEMENTS**  
**Bid Opening Date: September 8, 2016**

This addendum is hereby incorporated into the bid documents of the projects referenced above. The following items are clarifications, corrections, additions, deletions and / or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by strikethrough.

- A. The Bid Opening Date is remains September 8, 2016 at 2:00p.m.
- B. The Following are Drawings/Specification Changes:
1. Sheet M-301 HVAC Details; Detail 1 – Removed the words “Connect to existing duct”.
  2. Sheet M-301 HVAC Details; Detail 2 – Renamed “Automatic Flow Control Device” to “Flow Control Device”. Removed the words “Connect to existing piping at flex connection (typ.)” and replaced with “Flex connection”. Added note 4 which reads “If coil is being repiped, contractor may reuse existing chilled water control valve, flow control device, thermometers and pressure gauges.”
  3. Sheet M-301 HVAC Details; Detail 3 – Renamed “Automatic Flow Control Device” to “Flow Control Device”. Removed the words “Connect to existing piping at flex connection (typ.)” and replaced with “Flex connection”. Added note 4 which reads “If coil is being repiped, contractor may reuse existing chilled water control valve, flow control device, thermometers and pressure gauges.”
- C. **All other terms, conditions and specifications remain the same.**

**The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.**




**Receipt acknowledged by:**

\_\_\_\_\_  
**Authorized Signature**

\_\_\_\_\_  
**Date Signed**

\_\_\_\_\_  
**Title**

\_\_\_\_\_  
**Name of Firm**



**ATKINS**

402 SOUTH WELLS ROAD  
ORLANDO, FL 32810  
PHONE: 407.847.7275 FAX: 407.742.8888

CONSULTANT



PROJECT NAME

**ORANGE COUNTY  
COURTHOUSE AHU REPLACEMENT**  
425 N. ORANGE AVE. FLORIDA 32801  
100045182

No.	Date	Description
1	09-09-18	ADDENDUM 4

ISSUE LOG  
PROFESSIONAL SEALS

DAVID L. HERDMAN P.E.  
FLORIDA REG. NO. 7078

SHEET TITLE

**HVAC DETAILS**

SHEET INFORMATION  
JOB No. 100045182 Date Issued JUNE 3, 2018  
Designed By: CSR Sheet Number  
Checked By: DJH  
DC Number: T.F.  
Phase: 80

**M-301**