

November 2, 2016

**BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA**

**INVITATION FOR BIDS #Y17-139-LC
GREASE TRAP CLEANING, MAINTENANCE AND REPAIR FOR OCCC
TERM CONTRACT**

ADDENDUM NO.2

This addendum is issued to provide clarifications/responses to questions received.

1. Question: How far are the inside traps from outside access?

Answer: From the dock is 430 feet.

2. Question: How deep usually are the outdoor grease tanks from ground level to the top of the grease level?

Answer: 10 feet.

3. Question: What horsepower are the lift station pumps?

Answer: 2hp.

4. Question: What dimensions are the lift station wet wells?

Answer: The wells are 4 feet in width and 11 feet deep.

5. Question: Are there guide rails for the pumps on the lift stations?

Answer: Yes, the pumps have guide rails.

ACKNOWLEDGEMENT OF ADDENDA

a. The bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.

b. Receipt acknowledged by:

Authorized Signer

Date Signed

Title

Name of Bidder
IFB #Y17-139-LC
Addendum No. 2
Page 1 of 1