

August 18, 2016
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
IFB NO. Y17-701-CC/ADDENDUM NO. 2
REGIONAL COMPUTING CENTER A SIDE POWER FEED AND EMERGENCY
GENERATOR REPLACEMENT

REVISED BID OPENING DATE: September 8, 2016

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

- A. The bid opening has been changed from ~~August 23, 2016 at 2:00 p.m.~~ to September 8, 2016 at 2:00 p.m.

B. SITE VISIT

A site visit will be conducted on August 22, 2016 at 2:00 p.m. Meet at the Regional Computing Center, 4300 South John Young Parkway, Orlando, FL 32839.

C. Additions, Deletions and Clarifications

1. **Clarification:** Please get the following clarified. Sheet E 2.1 shows several new feeders for the AC system. Please furnish the feeder sizes for the AC units.

Answer: The intent is to match the existing wire sizes to AC units. For pricing, size the wiring to the breakers feeding the units.

2. **Clarification:** Sheet E2.1 shows all the existing AC feeders Numbers to HPCU written in black instead of gray. Please advise if there is any significance in black numbers.

Answer: No significance. The Condensing units will remain fed from HPCU panels.

D. Another addendum is forthcoming.

E. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of

acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.

- b. All other terms and conditions of the IFB remain the same.
- c. Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm