

October 27, 2016

BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
ADDENDUM NO. 2 / IFB NO. Y17-710-PH

PUMP STATIONS 3728 ROCKET BLVD. EXT, 3426 CYPRESS PARK, 3192R
ROCKET BLVD AND CENTRAL FLORIDA PARKWAY IMPROVEMENTS
PACKAGE 2

REVISED BID OPENING DATE: ~~November 1,~~ **3, 2016**

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

A. The Bid Opening Date is changed to November 3, 2016 at 2:00 P.M.

B. CLARIFICATIONS

1. Q: Antenna/SCADA pole on E-302. The information on ED-101 does not clarify as to what size the pole needs to be at the 1815 Rocket Blvd location. Please specify the size the county needs at this location.

A: **The referenced SCADA pole is actually for PS 3192R, which will be located at 10971 Rocket Boulevard. The electrical design for this station is shown on E-302. The pole height at this location is 50 feet.**

C. ACKNOWLEDGEMENT OF ADDENDA

a. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of proposal.

All other terms, conditions and specifications remain the same.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm

Oct. 27, 2016
Y17-710-PH, Add 2

Page 1 of 1