

December 5, 2016

BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA

ADDENDUM NO. 7 / IFB NO. Y17-711-PH

SOUTH WATER RECLAMATION FACILITY FATS OILS AND GREASE (FOG)
AND SEPTAGE RECEIVING STATION

BID OPENING DATE: December 13, 2016

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by **underlining**, deletions are indicated by ~~striketrough~~.

A. The bid opening remains December 13, 2016 at 2:00 P.M.

B. BIDDER QUESTIONS

- 1. I have taken a look at the plans for Y17-711 and I cannot find any information for survey control or to tie down the proposed improvements so they can be laid in the field by a surveyor. Am I just looking in the wrong place? Please clarify where that information may be found.**

Response: Project does not have a survey control. Project improvements are to be constructed relative to existing structures. The FOG Station containment and canopy are to be constructed around and over the existing containment area as shown on Drawing S02. The septage receiving station elevated pad dimensions are referenced on Drawing S05. Locations of new structures should be scaled relative to the existing septage structure. Surveyor will be required to establish permanent benchmarks and provide record drawings of constructed improvements per Specification Section 1050.

C. ACKNOWLEDGEMENT OF ADDENDA

- a. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of proposal.
- b. All other terms, conditions and specifications remain the same.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm