

November 21, 2016
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
Y17-715-MM / ADDENDUM # 2
ORANGE COUNTY CONVENTION CENTER
NORTH/SOUTH BUILDING EXTERIOR ELECTRICAL, WATER & PARKING
UPGRADES

Revised Bid Opening Date: November 29, 2016

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The Bid Opening Date is changed from ~~November 22, 2016~~ to **November 29, 2016 at 2:00 P.M.**

B. The following are questions/responses/clarifications:

1. Question: One of our asphalt providers ask for clarifications about the type of asphalt mix required. On the drawings it requires Type S-III, but in the specifications refer to Superpave. Please provide which one is the correct product to use.

Response: Provide Type S-III as listed on the plans and disregard the Superpave specifications (see part C of this addendum).

C. CHANGES TO SPECIFICATIONS:

1. This addendum includes clarifications, corrections, additions, deletions, and revisions that take precedence over the original bid documents. Below is a list of the information contained herein.
 - a. **Section 321216 Superpave Asphaltic Concrete; remove the section in its intirety.**
 - b. **Table of Contents, Division 32 – Exterior Improvements, strike 321216 Superpave Asphaltic Concrete.**

D. All other term and conditions of the IFB remain the same.

- E. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the proposal.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm