

November 23, 2016
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
Y17-715-MM / ADDENDUM # 3
ORANGE COUNTY CONVENTION CENTER
NORTH/SOUTH BUILDING EXTERIOR ELECTRICAL, WATER & PARKING
UPGRADES
Bid Opening Date: November 29, 2016

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The Bid Opening Date remains November 29, 2016 at 2:00 P.M.

B. The following are questions/responses/clarifications:

1. **Question:** The super-pave specification section 321216, included in the bid package, limited the RAP use to less than 20%. This specification was removed by Addendum #2. Does this mean that the Orange County 2010 Standard Specifications apply, i.e., limiting the RAP use to 30% max? What is the maximum RAP use allowed for this project?

Response: The 30% RAP is acceptable per County standard.

2. **Question:** We hereby respectfully request clarifications on the percent of RAP content in the Type S-III asphalt mix. Will the County require 20%, 30% or 45% of RAP in the asphalt mix?

Response: See response for item #1 above.

C. All other term and conditions of the IFB remain the same.

D. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the proposal.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm