

March 20, 2017

BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA

**Y17-736-MM / ADDENDUM # 4
ORANGE COUNTY CONVENTION CENTER
NORTH/SOUTH BUILDING DEMARC, MDR AND MDF ROOMS HVAC UPGRADES**

Bid Opening Date: March 23, 2017

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The following information is provided to answer a question from a prospective bidder:

Question: We have been advised that due to your Fire Alarm system being proprietary, we would not be able to work on it. Do you have a fire alarm contractor for this job? Please advise. **Answer:** The OCCC F/A is a proprietary system for Simplex Grinnell. **"If"** the contractor's work requires to move, re-locate or alter the fire alarm system devices, they will have to contact Simplex Grinnell, for them, to move, re-locate or alter the existing fire alarm system.

B. All other terms and conditions of the IFB remain the same.

C. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the proposal.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm