

April 21, 2017

**BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA**

**ADDENDUM NO. 4 / IFB NO. Y17-743-RM
BARRY STREET DRAINAGE IMPROVEMENTS PROJECT**

BID OPENING DATE IS APRIL 27, 2017

This Addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

A. The bid opening date remains April 27, 2017.

B. The following are questions/responses/clarifications:

1. **Question:** Plan sheet 12 calls out optional base group 9. Can the County add a pay item for this work?

Response: Per Section 430 of the FDOT Standard Specifications, the cost of site restoration for areas that are disturbed for the purpose of constructing pipes is to be included in the cost of the pipe. Therefore, the cost of Optional Base Group 9 is included in the cost of the pipe that is being installed/replaced. This is also stated in the project technical specifications (Part H) in the Basis of Payment section of TP 430.

C. All other terms, conditions and specifications remain the same.

The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm