

APRIL 2, 2018
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
Y18-739-EB / ADDENDUM NO. 2
DOCTOR LOVE ROAD SIDEWALK IMPROVEMENTS

THE OPENING DATE IS APRIL 5, 2018

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The Bid opening date remains April 5, 2018 at 2:00 p.m.

B. Questions and Answers:

1. **QUESTION:** On Sheet 16 of the Plans at Sta.114+45, does the County want EX-33 Headwall removed and a new MES installed?

ANSWER: No, the headwall won't be removed, no new MES is needed, see information below:

The original survey showed a headwall. Near the end of the design process, we believe either maintenance or roads and drainage performed some safety upgrades and installed an MES at EX-33. In lieu of getting the corridor re-surveyed, we placed an approximate location of the MES. Because we were not certain if the headwall was removed, we show both the headwall and the MES, often times when extending a cross drain or side drain that has an existing headwall, the headwall is partially or fully left intact and the new pipe is connected via a concrete collar as shown in FDOT index 430-001 (formally index 280). The intent is to leave the existing MES in its current condition.

2. **QUESTION:** Can aluminum handrail be used in lieu of galvanized?

ANSWER: The intent is to match the material of the existing railing

3. **QUESTION:** Is a Project Identification Sign required for this project? If so, how many?

ANSWER: The intent is to not require a Project Identification Sign.

C. All other terms and conditions of the IFB remain the same.

The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm