

August 7, 2018

BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
IFB NO. Y18-780-TA/ ADDENDUM NO. 2

BERRY DEASE WATER MAIN EXTENSION AND FORCE MAIN REPLACEMENT
PROJECT

BID OPENING DATE: ~~August 7, 2018~~ August 14, 2018

This Addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

A. Bid Opening Date has changed from ~~August 7, 2018~~ to August 14, 2018.

B. QUESTIONS AND ANSWERS

1. Q: Section 1570 Traffic Control Status: Submit a Maintenance of Traffic Plan signed and sealed by a registered engineer licensed in the State of Florida. Will submission by Certified Advance MOT Traffic Manager be acceptable as well?

A: No, MOT plan must be signed and sealed by a registered engineer licensed in the State of Florida.

2. Q: When a combination of conditions in the substrata, water table, or method of disposal may be encountered during the course of the work which makes dewatering impossible, or possible only through the use of unusual methods, the cost of which is excessive. Will the contractor be allowed to use an alternative method of construction and install the pipe under water to save the County the excessive costs?

A: No, the Contractor shall not be allowed to use an alternative method of construction and install the pipe under water.

3. Q: Section 1010, 1.03 States: The CONTRACTOR may be required to perform certain work at times of the day or night when system flows, vehicular traffic and pedestrian traffic are at diminished levels and at times appropriate to other activities which are occurring that may affect the project. These times may include but not be limited to the school start and end times occur. The CONTRACTOR shall comply with requirements to inspection fee of \$50 per hour being that it's outside the 7am-7pm thresh hold?

- A: Yes, Contractor shall comply with County requirements.
4. **Q: Please provide Geotechnical Reports for this project.**
- A: There is no geotechnical Report for this project.
5. **Q: Will the Orange County accept MBE Contractor from Miami-Dade County to satisfy the M/WBE requirement?**
- A: No. Refer to page C-9 of the IFB. All M/WBE must be certified by Orange County. The M/WBE directory is available by email or on our Business Development Division web site at Orangecountyfl.net. All firms must be certified prior to bid opening and must be certified in the area(s) for which they will be used.
6. **Q: Section 1065, 3. States: the Contractor shall be responsible for scheduling and paying for all inspection services associated with the Building Permit in order to obtain final approval. What are the inspection fees required by the Building Permit?**
- A: No building permit is required for this Project. Delete ~~Section 1065, Item 3~~ from the technical specifications.
7. **Q: Section 1560, A. States: The Contractor shall prepare and submit an Erosion and Sedimentation Control Plan (Stormwater Pollution Prevention Plan) for County review and approval. The Plan shall be in effect throughout the Construction duration. Is this plan required to be signed and sealed by a Florida Registered Professional Engineer?**
- A: Yes, this plan shall be signed and sealed by a Florida Registered Professional Engineer.
8. **Q: What is the material and depth required to Restore Stabilized Dirt Road?**
- A: Refer to specification section 02570. Stabilized roads shall be equivalent to the stabilized subgrade requirements to a minimum thickness of twelve inches.

9. Q: Please provide Concrete Pile Cap Detail.

A: Concrete Pile Cap Detail is already contained in plans on sheet D-130.

B. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of proposal.
- b. All other terms, conditions and specifications remain the same.
- c. Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm