

June 5, 2019

**ADDENDUM #1
INVITATION FOR BIDS #Y19-1125-AV**

**COMMUNITY CENTER SECURITY ALARM MONITORING,
INSPECTION, REPAIR, AND INSTALLATION SERVICES**

This Addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original documents; Additions are indicated by **underlining** and deletions via ~~strikethrough~~.

A. Opening date remains unchanged, Thursday, June 20, 2019, at 2:00PM (local time)

B. Questions and Answers:

1. **Question:** What is the current intrusion system in place today? We need to ensure we have the certifications and partnerships to perform maintenance and programming on that system.

Answer: The current intrusion system in place is DSC with analog phone lines.

2. **Question:** How many edge devices are in place? (i.e. glass breaks, door position switches, motion detectors, panels) This is to determine the cost of the annual maintenance agreement we will develop and present to Orange County for this project.

Answer: There are approximately 200 door and window contacts and 129 motion sensors in our 27 sites.

3. **Question:** How many zones per each of the 27 sites? This will provide us the complexity of the current intrusion system in place.

Answer: There are up to 6 zones per each of the 27 sites.

4. **Question:** There is a \$20,000 parts identifier, however no mention of any parts that are required. How many facilities are expected to need new intrusion panel and associated equipment? We need to know this in order to determine if we can meet the budget requirement.

Answer: The \$20,000 budget is to upgrade or install systems to include 1 master control panel, 1 fixed English touchpad, and an interactive modem for wireless interactive monitoring.

All other specifications, terms and conditions remain the same

ACKNOWLEDGEMENT OF ADDENDA

a. The bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned no later than the date and time for receipt of the bid or proposal.

b. Receipt acknowledged by:

Authorized Signer

Date Signed

Title

Name of Bidder