

March 20, 2019

BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA

Y19-742-EB / ADDENDUM # 1
WINTER PARK PINES OUTFALL CANAL E-03-H

Bid Opening Date: March 26, 2019

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

- A. The following information is provided to answer questions received from prospective bidders:
1. **Question:** It is unclear where the proposed easement is in order to access the work location. There will be heavy equipment and cranes needed for this project. Please identify a wide enough easement from the main road that can be utilized. **Answer:** The drainage R/W along this portion of the E-03-H canal is 80 feet in width. This right-of-way includes a 30-foot maintenance berm along the south edge of the canal with a gate to access the site off North Forsyth Road.
 2. **Question:** Please provide a location for a contractor's staging area for equipment and materials to be stockpiled. **Answer:** The 30-foot maintenance berm east of the project area could be used for staging but in accordance with Part G of the special provisions the Contractor shall submit to Orange County a proposed temporary staging area for review and approval prior to construction.
- B. All other terms and conditions of the IFB remain the same.
- C. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the proposal.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm