

**September 18, 2019**  
**BOARD OF COUNTY COMMISSIONERS**  
**ORANGE COUNTY, FLORIDA**  
**Y20-706-TA / ADDENDUM # 3**  
**WESTERN REGIONAL WATER SUPPLY FACILITY IMPROVEMENTS PHASE 3A**  
**PART 2**

**Bid Opening Date: September 24, 2019**

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

**A. CLARIFICATIONS**

1. **Q:** What is the pipe type and pressure rating for the 2 – 54 Inch Line Stops?

**A:** Based on project as-built information, the existing 54-inch steel main is per AWWA C-200/ASTM A139 Grade B and is 3/8-inch thick. The main is cement lined in accordance with AWWAC205 and tape coated per AWWA C214. Design pressure on the 54-inch main downstream of the high service pump is 65-75 psi. There is no steel mesh in the discharge line.

**B.** All other terms, conditions, and specifications of the IFB remain unchanged.

**C.** The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the proposal.

**Receipt acknowledged by:**

\_\_\_\_\_  
**Authorized Signature**

\_\_\_\_\_  
**Date Signed**

\_\_\_\_\_  
**Title**

\_\_\_\_\_  
**Name of Firm**