

**November 4, 2019**  
**BOARD OF COUNTY COMMISSIONERS**  
**ORANGE COUNTY, FLORIDA**  
**IFB Y20-712-RC / ADDENDUM 4**  
**MICHIGAN CAMPUS PARKING IMPROVEMENTS**

**THE REVISED PROPOSAL DUE DATE IS: November 12, 2019**

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

**A. The bid opening date changed from ~~November 7, 2019~~ to November 12, 2019 at 2:00P.M.**

**B. Questions/Answers/Clarifications.**

1. Questions:

- i. Question: The Project Documents require new panels, Are the panels that are referenced existing? If they are existing, please provide the following information :

Panel A, Panel B, & Panel C – Manufacture, models, AIC Rating, breaker type, bolt-on or Plug-in.

Answer: **Panel A**

Manufacturer: Square D

Model: NQ

AIC Rating: 10K

Breaker Type: Standard

Bolt-on or Plug-in: Assume Bolt-on. (to be verified by Contractor)

**Panel B**

Manufacturer: GE

Model: A Series

AIC Rating: 10K

Breaker Type: Standard

Bolt-on or Plug-in: Assume Bolt-on. (to be verified by Contractor)

**Y20-712-RC**  
**Addendum 4**  
**November 4, 2019**

**Panel C**

Manufacturer: Eaton

Model: PRL1A

AIC Rating: 10K

Breaker Type: Standard

Bolt-on or Plug-in: Assume Bolt-on. (to be verified by Contractor)

- C. All other terms and conditions of the IFB remain the same. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.**

**Receipt acknowledged by:**

\_\_\_\_\_  
**Authorized Signature**

\_\_\_\_\_  
**Date Signed**

\_\_\_\_\_  
**Title**

\_\_\_\_\_  
**Name of Firm**