

August 4, 2017

BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA

ADDENDUM NO. 1

IFB #Y17-644-PD
Boiler Replacement for Orange County Convention Center Building 12

The above Invitation for Bids is amended as follows:

1. **ADD ATTACHMENT A, Drawing of currently installed boilers. Use the attached link to access the drawings:**

<ftp://ftp.ocfl.net/divisions/Purchasing/pub/Current%20Bids%20and%20RFPs%20-%20Large%20Files/Y17-644-PD/>

2. Question: Does the bidding contractor have to include provisions for “sign and sealed” drawings that reflect the scope of work?

Answer: Yes, when the entire job is completed including plumbing, mechanical and electrical.

3. Question: Will the scope of work require new balancing valves attached to the new sections of HHW piping?

Answer: No, only what it currently written in the scope of work will be required.

4. Question: Fuel oil will not be used with the new HHW replacement boilers?

Answer: No, we will only be using Natural Gas.

5. Question: Does the bidding contractor have to include provisions for chemical treatment to the new HHW?

Answer: No, this will be handled by the current servicing contractor.

6. Question: Existing mechanical room has four expansion tanks. Only two tanks need to be removed from the mechanical room?

Answer: Yes, only two tanks are to be removed.

7. Question: Will new HHW boiler require a separate fused disconnect switch be mounted near the boiler in addition to a new Motor Control Panel?

Answer: No, there will be a shunt/trip installed upon completion of the project.

8. All other specifications, terms and conditions remain the same.

ACKNOWLEDGEMENT OF ADDENDA

- a. The bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.

- b. Receipt acknowledged by:

Authorized Signer

Date Signed

Title

Name of Bidder