

May 7, 2019

BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA

Y19-743-EB / ADDENDUM # 2

HUBBARD ROAD (DW-055) DRAINAGE WELL REHABILITATION

New Bid Opening Date: May 14, 2019

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The bid opening date is hereby changed from ~~May 9, 2019~~ to May 14, 2019.

B. Answers to questions submitted by interested bidders:

1. **Question:** : In Section -1 General Requirements, It says that the 20” existing casing will be scrubbed, and milled out with a 19” bit prior to the 16” steel liner casing being installed. Is it the correct understanding that the Contractor is required to run both casing scrub brushes and also run a 19” bit to the bottom of the existing 20-inch casing depth?
Answer: Yes.
2. **Question:** What is the required GPM of the test pump from the well head discharge?
Answer: 1500gpm.
3. **Question:** What is the expected date of NTP? **Answer:** The anticipated date of Notice to Proceed is the second week in July 2019.
4. **Question:** Will the Engineer please give a time frame that the Contractors can base the development period on for bidding purposes? **Answer:** The contractor shall provide up to 4 hours development time.
5. **Question:** The Specifications speak of a 16” 0.375 wall liner, however the annular space will be less than 2-inches. The specifications say 20”, however, the caliper log reflect around 19” giving 1.50” for an annular. Is the 16” 0.375 wall liner correct, or is it 14” 0.375 wall? **Answer:** The 16” 0.375 wall steel casing is correct. On May 21, 2018, CDM Smith submitted a letter request to rehabilitate existing Hubbard Road Drainage Well (DW-055) to the FDEP discussing the 16” 0.375 wall steel liner and annulus of less than 2”. FDEP approved the request and plans and specifications on November 16, 2018.
6. **Question:** The work site has an overhead power line that is in very close proximity of the well, and will require removal for a drilling rig or crane to work, especially with the work detail for this project, if anything happened it could result in electrical shock of crew. Will the County assist in temporary power relocation? **Answer:** The Contractor is responsible for all utility clearance. The County’s Consultant will assist the Contractor to determine the power provider and information on what can be done to provide a safe working environment as it relates to the electrical power near the well site.

C. All other terms and conditions of the IFB remain the same.

D. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the proposal.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm