

March 28, 2017
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
ADDENDUM NO. 5 / IFB NO. Y17-740-CC
CORRECTIONS HORIZONS AHU HOT WATER REPLACEMENT

BID OPENING DATE: April 4, 2017

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The bid opening date remains April 4, 2017 at 2:00 p.m.

B. Questions and Answers:

Question: From the temporary boiler to the pump room, will the HHW or gas piping need to be insulated?

Answer: The HHW piping will require insulation. The gas piping does not require insulation.

C. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.
- b. All other terms and conditions of the IFB remain the same.
- c. Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm