

April 3, 2017
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
ADDENDUM NO. 7 / IFB NO. Y17-740-CC
CORRECTIONS HORIZONS AHU HOT WATER REPLACEMENT

BID OPENING DATE: April 11, 2017

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The bid opening date remains April 11, 2017 at 2:00 p.m.

B. Questions/Answers:

Question: Contractor has additional information concerning the pumps with the Engineer's answer "that pumps shall be rated for 250 PSI" as noted in the specifications section 15185-2. End suction and in-line pumps have cast iron casing rated for 175PSI. Some end suction pumps are available with a ductile iron casing that will allow the 250 PSI rating. However, the specification calls for cast iron pump casing. If in fact 250PSI pumps are required then pumps would need to be horizontal split case and vertical split case type. Pump TDH does not reflect the need for 250 PSI casings."

Answer: The pump casing does not have any bearing effect on maximum working pressure rating. A stuffing box seal in lieu of standard seals would allow the pumps to achieve the stated working pressure and temperatures as noted in contract drawings.

C. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.

D. All other terms and conditions of the IFB remain the same.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm