

September 21, 2017
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
ADDENDUM NO. 5 / IFB NO. Y18-700-CC
ORANGE COUNTY CORRECTIONS HORIZONS ELEVATOR MODERNIZATION

BID OPENING DATE: September 26, 2017

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The bid opening date remains September 26, 2017 at 2:00 P.M.

B. Questions and Answers:

- 1. Question:** What is the manufacturer of the existing panels and AIC ratings of existing circuit breakers? We will be basing our bid on SqD panels with minimum standard AIC ratings of 10kAIC for 120/208/240V and 14kAIC for 277/480V pending verification of exist equipment. Additional cost that may be required will adjusted accordingly should higher ratings be required.
Answer: The existing panels are GE. Existing AIC rating of EL7A and L7A are 10kaic, verify on site existing AIC rating of EQHRE.
- 2. Question:** What are the cabling requirements for Low Voltage Data/Comm outlets? What are the spec requirements for the cabling wire to be used: number of conductors, insulation, etc. Where are the cables coming from and what do they tie into? Low voltage items will be excluded pending point-to-point confirmation & type of termination points.
Answer: There are no new low voltage data/comm. outlets. The only connection would be telephone to the elevator and that is to be disconnected and preserved for connection to new elevators.
- 3. Question:** The location of L7A and EL7A? Drawing E102, Power Note 10 states that these panels are in a 7th fl electrical room near the elevators. Pending confirmation of actual location, all circuits to the panels will be based on approx. 80 lf from center of double doors on level 8 (detail 3, drawing E201).
Answer: EL7A and L7A are located on the 7th floor directly next to either elevator shaft; 80 lf is an acceptable estimate from double doors on level 8 (detail 3 drawing E102).

4. Question: What are the dimensions of the freight elevator?

Answer: All elevators will be the same size as per the specifications. Refer to specifications 14220 1.01 A. (4 35000lb Geared Passenger/Prisoner Elevators. State #'s 45030-45033).

ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.
- b. All other terms and conditions of the IFB remain the same.
- c. Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm