

**JULY 9, 2018**  
**BOARD OF COUNTY COMMISSIONERS**  
**ORANGE COUNTY, FLORIDA**  
**ADDENDUM NO. 1, IFB Y18-778-RC**  
**TIBET BUTLER PRESERVE HVAC SYSTEM REPLACEMENT**  
**Bid Opening Date: JULY 17, 2018**

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strike through~~.

A. Bid opening date remains July 17, 2018 at 2:00 p.m.

B. Questions and Answers:

1. **QUESTION:** What is the make and model of the existing fire alarm system?  
**ANSWER:** The existing system is a Silent Knight, SK-5208.
2. **QUESTION:** Sheet E101 shows an external wall mounted light L1 on the outside wall of the Exhibit Area 101. Please furnish the make and model # of the light.  
**ANSWER:** The Luminaire L1 is not new, it is existing and this is the relocated location on E101. See sheet E100 where direction to remove and relocated is identified.
3. **QUESTION:** Sheet E101, Note #7, requires a step-down transformer 120/24V. Please furnish the size (KVA rating) of the transformer.  
**ANSWER:** Transformer is for mechanical controls and shall be sized per the needs of the Division 15 controls contractor. Coordinate with division 15 controls contractor.
4. **QUESTION:** Sheet E101, Note #6, requires to relocate the turtle dwelling/heater. Please furnish the size of the heater.  
**ANSWER:** E101 shows the estimated location. See E100 for the existing location which would have conflicted with the new packaged unit. Existing name plate data and conductors for the existing heater shall be field verified by the contractor. Based on the existing panels it does not appear to be more than #12 conductors and 120V.
5. **QUESTION:** Sheet E101, there is a note on the electrical service requires providing new fuses. Please furnish the size of the electrical service or the fuses required.  
**ANSWER:** The only fuses referenced are those associated with the fused disconnects called out for the new CUs, etc. 20/30, 60/100, etc as defined on the

legend the top number indicates the fuse rating and the bottom number is the disconnect rating. As indicated on the legend. Please ensure you have all drawings and specifications drawings.

C. ACKNOWLEDGEMENT OF ADDENDA

1. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.

2. All other terms and conditions of the IFB remain the same.

**3. Receipt acknowledged by:**

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date Signed

\_\_\_\_\_  
Title

\_\_\_\_\_  
A. Name of Firm