

July 3, 2019  
BOARD OF COUNTY COMMISSIONERS  
ORANGE COUNTY, FLORIDA  
Y19-1128-RM / Addendum No. 4  
**ASPHALT MILLING AND RESURFACING WITH FRICTION COURSE AND ASPHALT  
BERMS**  
**BID OPENING DATE IS July 11, 2019**

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

**A.** The bid opening date remains July 11, 2019.

**B. The following are questions/responses/clarifications:**

1. The Document states "PG76-22 asphalt binder meeting the requirements of 916 FDOT Standard Specifications for Road and Bridge Construction can be used." Understanding that the County is not requiring PG76-22 in the SP-12.5 Items, Berms, Leveling, etc. please clarify that PG76-22 is required for the FC-9.5 items.

**Response:** All mixes used under this contract shall be FDOT approved and adhere to contract specifications inclusive of containing no more than 25% RAP. The same mix design approved by the County must be used for the duration of each project unless otherwise specified by Orange County. There are no exceptions for alternate mix designs regarding leveling, base repairs or berms.

**C. All other terms, conditions and specifications remain the same.**

**The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.**

**Receipt acknowledged by:**

\_\_\_\_\_  
**Authorized Signature**

\_\_\_\_\_  
**Date Signed**

\_\_\_\_\_  
**Title**

\_\_\_\_\_  
**Name of Firm**