

November 6, 2018

**BOARD OF COUNTY COMMISSIONERS  
ORANGE COUNTY, FLORIDA  
ADDENDUM NO. 5 / IFB NO. Y19-706-EB**

**FORCE MAIN WEST AREA PACKAGE 2**

**BID OPENING DATE: November 13, 2018**

This Addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

**A. BID OPENING DATE**

**The Bid Opening date shall remain as follows:**

November 13, 2018 at 2:00 P.M.

**B. CLARIFICATIONS**

**1. Q: Please provide additional clarification to Question No. 6 in Addendum 3. The question was: There is no bid item for high early strength concrete used in the asphalt pavement restoration. Can we use soil cement in lieu of high early strength concrete?**

A: The cost of high early strength concrete indicated in Figure A612 and in Figure A613 on Sheet D-102 of the plans is included in the associated Pay Item: "Pay Item 22 – Road Crossing Pavement Restoration". Please refer to the revised Bid Form issued in Addendum No. 3. Also refer to Pay Item 22 in the Revised Specification Section 01025 – Measurement and Payment issued in Addendum No. 3.

Soil cement cannot be used in lieu of high early strength concrete at road crossings.

**C. ACKNOWLEDGEMENT OF ADDENDA**

1. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of proposal.

2. All other terms, conditions and specifications remain the same.

3. Receipt acknowledged by:

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date Signed

\_\_\_\_\_  
Title

\_\_\_\_\_  
Name of Firm