

March 1, 2019

BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA

Addendum No. 1/IFB Y19-735-TA

GRAVITY SYSTEM IMPROVEMENTS PACKAGES 15,19,20,21,22

Revised Bid Opening Date: March 12, 2019

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

A. The Bid Opening Date is revised from ~~March 5, 2019~~ to March 12, 2019

B. CLARIFICATIONS

1. Q: Bid schedule Item #16 show 332 Vertical Feet of manhole, where overall heights of manholes from page C-1 to C-13 (schedule on (North) and (South) example C-3 and C-4 show the same manhole and pipes) comes to 177 VF.

A: Bid Item #16 indicates 332 VF for the entire project including sheets C-1 to C-33. The quantity is verified.

2. Q: Bid schedule item #20 show 75,855 LF of 8" diameter CIPP liner, where overall length of 8" pipe from page C-1 to C-13 is 27015 LF.

A: Bid Item #20 indicates Sanitary Sewer Main CIPP Liner (8" diameter) for the entire project including sheets C-1 to C-33. The quantity is verified.

3. Q: Bid schedule item #21 show 7199 LF of 10" diameter CIPP liner, where overall length of 10" pipe from page C-1 to C-13 is 4719 LF.

A: Bid Item #21 indicates Sanitary Sewer Main CIPP Liner (10" diameter) for the entire project including sheets C-1 to C-33. The quantity is verified.

4. Q: Is Refratta Hac 100, Calcium Aluminate Repair Mortar an acceptable and approved material to bid for Manhole Rehabilitation?

A: No, Per Section 01301, Base all bids on materials listed in Appendix D. This material is not listed in Appendix D and is not approved.

B. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the proposal.

C. All other terms and conditions of the IFB remain the same.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm