

March 21, 2019

BOARD OF COUNTY COMMISSIONERS  
ORANGE COUNTY, FLORIDA  
IFB NO. Y19-740/ ADDENDUM NO. 1

CHILLER REPLACEMENTS AT  
UTILITIES ADMINISTRATION BUILDING

REVISED BID OPENING DATE: APRIL 2, 2019

This Addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

**A. Bid Opening Date has been revised from ~~March 26, 2019~~ to April 2, 2019.**

**B. CLARIFICATION**

The contractor shall maintain cooling for the large, 2<sup>nd</sup> Floor Server Room at all times - 24 hours a day, 7 days a week. This Server Room is served by air handlers (AC-1 and AC-2) connected to the chilled water system. Both chillers cannot be offline simultaneously without accommodations for temperature control of the Computer Room.

**C. ACKNOWLEDGEMENT OF ADDENDA**

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of proposal.
- b. All other terms, conditions and specifications remain the same.
- c. Receipt acknowledged by:

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date Signed

\_\_\_\_\_  
Title

\_\_\_\_\_  
Name of Firm