

April 15, 2019
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
ADDENDUM NO. 1 / IFB NO. Y19-746-RC
ORANGE COUNTY CORRECTIONS BUILDING A HVAC UNIT REPLACEMENT

THE REVISED BID OPENING DATE IS: April 25, 2019

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. **The bid opening date has been revised from ~~April 16, 2019~~ to April 25, 2019 at 2:00 P.M.**

B. Questions and Answers:

1. **Question:** Panel C in Electrical Room A147A does not meet clearance requirements. Please clarify new location to meet code.
Answer: See attached revised location. Panel C shall be located next to existing Panel IEQHI. Match and extend all existing wiring and conduit to new panel location. Relocate existing switch and receptacle on wall in new panel location. Relocate existing diffuser.

2. **Question:** Will any consideration be given to have equipment purchased separately?
Answer: No, all bids will be contractor supply and install. Owner direct purchase will not be used on this project.

C. **All other terms and conditions of the IFB remain the same. The Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.**

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm

April 15, 2019
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
ADDENDUM NO. 1 / IFB NO. Y19-746-RC
ORANGE COUNTY CORRECTIONS BUILDING A HVAC UNIT
REPLACEMENT

Comment During the walkthrough for this job it was pointed out that Panel C does not meet clearance requirements. Where would they like the new panel placed?

Response After a site walk by RTM a new location for Panel C has been identified in Electrical Room A147.

Panel C shall be located next to existing Panel IEQHI. Match and extend all existing wiring and conduit to new panel location. Relocate existing switch and receptacle on wall in new panel location. Relocate existing diffuser.

