

May 16, 2019
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
Addendum No. 1, IFB Y19-753-RC
PARKS MOSS PARK C-29 BOAT DOCK & MOORING REPAIRS

Bid Opening Date: May 21, 2019

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. The bid opening date remains May 21, 2019, 2019 at 2:00 P.M.

B. Additions, Revisions, Deletions, Clarifications, Questions and Answers:

1. **Question:** Will the bumper system be required with the alternate aluminum fixed pier and if so how will it be attached?

Answer: The bumpers will be required and will be attached to the timber piles in the same manner as detailed on section 2/C401. Minor modification will be made if this option is exercised.

2. **Question:** Do the 2 ladders shown in the demolition be replaced with new, if so what type?

Answer: The existing ladders shall be removed, stored and reinstalled as part of the new decking. As part of the alternate bid for fixed aluminum pier, provide provisions for two new ladders.

3. **Question:** Note in detail 3 states '... Min. 12' Embed...' Detail 1 and 2 show 10' min. Which depth is required, 10' or 12'?

Answer: 10 feet is embedment depth.

4. **Question:** Boardwalk/Sidewalk-Transition shows a mud line elevation of 86+/- and a top of walk elevation of 87.5. Other details show the mud line at +/- 56 and the top of deck at 63.8 +/- . Please clarify as this is a +/- 20' difference.

Answer: Boardwalk-Sidewalk transition detail 4/C401 has incorrect elevations. All other elevations C101 and C401 are correct. Please refer to plan view on sheet C101, Details 1/C401 and 2/C401.

C. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.
- b. All other terms and conditions of the IFB remain the same.
- c. **Receipt acknowledged by:**

Authorized Signature

Date Signed

Title

Name of Firm