

**August 27, 2019**  
**BOARD OF COUNTY COMMISSIONERS**  
**ORANGE COUNTY, FLORIDA**  
**IFB Y19-784-RC / ADDENDUM NO. 4**  
**ORANGE COUNTY CORRECTIONS PHOENIX CHILLER REPLACEMENT**

**REVISED BID OPENING DATE: SEPTEMBER 5, 2019**

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to, and shall take precedence over, the original documents. Underlining indicates additions, deletions are indicated by ~~strikethrough~~.

A. **The bid opening date has been revised from ~~August 29, 2019~~ to September 5, 2019 at 2:00 P.M**

B. Additions, Deletions and Clarifications

**Question:** Addendum 03, question 2 states the chilled water system cannot be shut down and refers to a temporary chiller if needed. Since the 2nd chiller is redundant and a specific phasing plan has been designed, why the new reference to a temporary chiller which adds cost to the County. Please confirm the intent is to replace one chiller/pump at a time leaving one chiller/pump operational and the Contractor does not need to include any money for a temporary chiller and the electric to operate it.

**Answer:** The intent of the phasing plan is to replace one chiller (CH-1) and one pump (CHP-1) at a time and leave the other chiller (CH-2) and pump (CHP-2) operational. Please follow this phasing plan as defined on sheet M-401. However, in the event that the existing chiller (CH-2) fails during the replacement of chiller 1, the contractor shall provide a temporary chiller to maintain the chilled water loop flow and temperature. The contractor shall be responsible for maintaining chiller and pump operation during construction and shall provide and connect a temporary chiller promptly if the existing chiller cannot be maintained.

C. All other terms and conditions of the IFB remain the same.

The Bidder/Proposer shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid or proposal.

**Receipt acknowledged by:**

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date Signed

\_\_\_\_\_  
Title

\_\_\_\_\_  
Name of Firm