

**October 25, 2019**  
**BOARD OF COUNTY COMMISSIONERS**  
**ORANGE COUNTY, FLORIDA**  
**ADDENDUM NO. 3 / IFB Y20-720-RM**  
**ORANGE COUNTY SOLID WASTE ADMINISTRATION BUILDING ROOF REPLACEMENT**  
**BID OPENING DATE: November 12, 2019**

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining; deletions are indicated by ~~strikethrough~~.

**A. The bid opening date remains November 12, 2019**

**B. The following are questions/responses/clarifications:**

1. While looking at the project manual, I read a statement which stated to remove all coping and edge metal, but in the drawings there is no mention of replacing the Coping on the top of the Western wall. The western wall is the one with the diagonal supports. Also in the plans there is photographs for the job sight in photograph 6. I can't tell if the sky lights have already been removed or if we will be removing the skylights and installing the steel decking.

**RESPONSE:** JAAI Response: The copings are not being replaced at the west wall. The existing metal expansion joint coping between the lower and upper roof is being removed and replaced. This is shown on photo 7/A5.2. All edge metal is being removed and replaced.

The skylights are to be removed and steel decking is to be installed per Scope of Work item 2.0 Existing Skylight Assemblies, which includes skylight removal (2.1) , skylight in-fill (2.2) and interior finishes (2.3).

2. Do we have to have a GC's License in order to bid this project or can we bid this under our Roofing License?

**RESPONSE:** The project requires structural, interior finishes and roofing. This typically requires a GC however, the Building Department will have the final decision. Larger roofing contractors typically are also General Contractors and should be able to complete each trade.

**A second walkthrough is schedule on November 1, 2019, 1:00 P.M.  
At Solid Waste Conference Room 5901 Young Pine Road, Orlando, Florida  
32829.**

**C. All other term and conditions of the IFB remain the same.**

**The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.**

**Receipt acknowledged by:**

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date Signed

\_\_\_\_\_  
Title

\_\_\_\_\_  
Name of Firm