

November 15, 2019
BOARD OF COUNTY COMMISSIONERS
ORANGE COUNTY, FLORIDA
ADDENDUM NO. 6 / IFB Y20-720-RM
ORANGE COUNTY SOLID WASTE ADMINISTRATION BUILDING ROOF REPLACEMENT
BID OPENING DATE: November 19, 2019

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining; deletions are indicated by ~~strikethrough~~.

A. The bid opening date remains November 19, 2019

B. The following are questions/responses/clarifications:

1. Are the finished interior ceilings at the skylight removal locations in the Administration Area going to be exposed painted metal decking?

RESPONSE: The ceiling will be exposed metal deck to match the existing. The ceiling will be painted with primer and two coats of topcoat to match existing. Roof fasteners will be painted also.

2. What are the exact requirements for the edge metal on this project? The specs/drawings state premanufactured ES—1 but also appear to call for shop fabrication. Also, the material called for is stated as both 316 and 304 stainless steel.

RESPONSE: Shop fabricated edge metal is acceptable out of type 304 steel.

3. Will the offices or working areas beneath the skylight removal locations and metal decking installation be vacant during construction?

RESPONSE: No, the facility will remain operational during this project.

C. All other term and conditions of the IFB remain the same.

The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of the bid.

Receipt acknowledged by:

Authorized Signature

Date Signed

Title

Name of Firm

Y20-720-RM
Addendum# 6